


<p>Dated on the</p> <p>26th day of February, 2010.</p>	 ALBERTA UTILITIES COMMISSION
--	--

<p>Appendix 1 to Decision 2010-090</p> <p>AltaLink Management Ltd. Time Extension to Alter Edgerton 899S Substation</p>	<p>Application No. 1605908 Proceeding ID. 502</p>
---	---

AltaLink Management Ltd. (Operator), pursuant to Permit and Licence No. U2009-202, issued as the disposition for Application No. 1602273, has approval to alter (Alteration) Edgerton 899S substation (Substation).

Clause 4 of Permit and Licence No. U2009-202 provided that the Alteration was to be completed by March 31, 2010. Clause 4 also provided that upon application by the Operator, the Alberta Utilities Commission (Commission) may stipulate a later date when the Alteration of the Substation shall be completed. The Operator, by Application No. 1605908 (Application), registered on February 17, 2010, applied to the Commission for an extension of time to complete the Alteration.

The Commission therefore, pursuant to section 19 of the *Hydro and Electric Energy Act*, approved the Application in Decision 2010-090, and pursuant to sections 14 and 15 of the *Hydro and Electric Energy Act* granted the Operator a Permit to alter and a Licence to operate the Substation, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act* (the Acts), any Regulations made under the Acts, any Orders made under the Acts, the Commission Rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The Substation shall be wholly located in the northeast quarter of Section 2, Township 44, Range 4, West of the 4th Meridian, and in the southeast quarter of Section 11, Township 44, Range 4, West of the 4th Meridian;
2. Specifications of the Substation shall be and include as follows:
 - (a) one 15/20/25-MVA, 138/25-kV transformer;
 - (b) two 138-kV circuit breakers;
 - (c) two 25-kV circuit breakers; and

- (d) an enclosure surrounded by a chain link fence and other substation equipment as described in the Application No. 1602273;
3. The Operator shall file with the Commission, within 30 days of completing the Alteration, the Energization Certificates for the Substation issued by the Alberta Electric System Operator and by the Operator respectively to confirm that the Alteration has been completed and is being operated in accordance with the provisions of this Permit and Licence;
 4. Unless otherwise authorized by the Commission, Alteration of the Substation shall be completed by November 30, 2010;
 5. The Commission may cancel or suspend this Permit and Licence, in whole or in part, in accordance with section 41 of the *Hydro and Electric Energy Act*, or may review this Permit and Licence, in whole or in part upon its own motion, or upon an application by an interested party, in accordance with section 10 of the *Alberta Utilities Commission Act*; and
 6. Permit and Licence No. U2009-202 is rescinded.

END OF DOCUMENT