


<p>Dated on the</p> <p>16th day of January, 2012</p>	 <p>The Alberta Utilities Commission</p>
<p>Appendix 2 to Decision 2012-018</p> <p>ENMAX Power Corporation Alter ENMAX No. 32 Substation Southeast Calgary</p>	<p>Application No. 1607215 Proceeding ID No. 1180</p>

ENMAX Power Corporation (ENMAX), pursuant to Permit and Licence No. EN98-22,<sup>1</sup> is the operator of ENMAX No. 32 substation. By Application No. 1607215 registered on April 19, 2011, ENMAX applied to the Alberta Utilities Commission (AUC or the Commission) for approval to alter and operate the substation in southeast Calgary.

The Commission, pursuant to Section 19 of the *Hydro and Electric Energy Act*, approved the application in Decision 2012-018,<sup>2</sup> and pursuant to sections 14 and 15 of the *Hydro and Electric Energy Act*, granted ENMAX this permit to alter and licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The substation shall be wholly located in the southeast quarter of Section 13, Township 23, Range 1, west of the Fifth Meridian at the municipal address of 1808 - 114 Avenue S.E. in the city of Calgary.
2. Specifications of the substation shall include the following:
  - one (1) 138/13.8-kilovolt (kV), 30/40/50 megavolt-ampere (MVA) transformer
  - two (2) 138/13.8-kV, 18/24/30-MVA transformers
  - one (1) 138-kV bus tie circuit breaker
  - three (3) 138-kV circuit breakers
  - associated substation equipment and an enclosure surrounding the substation perimeter as described in the application and other previous permits and licences pertaining to the substation
3. ENMAX shall file with the Commission, within 30 days of completing the alteration, the energization certificates for the substation issued by the Alberta Electric System Operator and by ENMAX, respectively, to confirm that the alteration has been completed and that the substation is being operated in accordance with the provisions of this permit and licence.

<sup>1</sup> Permit and Licence No. EN 98-22, Application No. 970516, January 5, 1998.

<sup>2</sup> Decision 2012-018: Alberta Electric System Operator – Needs Identification Document and ENMAX Power Corporation – ENMAX No. 32 Substation Capacity Upgrade, Applications No. 1607206 and No. 1607215, Proceeding ID No. 1180, January 16, 2012.

4. Unless otherwise authorized by the Commission the alteration of the substation shall be completed by January 31, 2013.

Permit and Licence No. EN98-22 is rescinded.

The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

END OF DOCUMENT