


<p>Dated on the</p> <p>23rd day of January, 2012</p>	 The Alberta Utilities Commission
Appendix 1 to DA 2012-12  AltaLink Management Ltd. Alter Hardisty 377S Substation	Application No. 1608066 Proceeding ID No. 1671

AltaLink Management Ltd. (AltaLink), pursuant to Permit and Licence No. [U2011-86](#),<sup>1</sup> is the operator of the Hardisty 377S substation. By Application No. 1608066 registered on January 19, 2012, AltaLink applied to the Alberta Utilities Commission (AUC or the Commission) for approval for a time extension to complete alterations to the substation.

The Commission, pursuant to Section 19 of the *Hydro and Electric Energy Act*, approved the application in DA 2012-12,<sup>2</sup> and pursuant to sections 14 and 15 of the *Hydro and Electric Energy Act*, granted to AltaLink this permit to alter and a licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The substation shall be wholly located Section 29, Township 42, Range 9, west of the Fourth Meridian.
2. Specifications of the substation shall include the following:
  - a) one 138/25-kilovolt (kV) transformer
  - b) six 138-kV circuit breakers
  - c) four 25-kV circuit breakers
  - d) one 44.9-megavolt ampere reactive (MVAR), 138-kV capacitor bank
  - e) one 27-MVAR, 138-kV capacitor bank
  - f) associated substation equipment
  - g) an enclosure surrounded by a chain link fence and other substation equipment as described in the application
3. AltaLink shall file with the Commission, within 30 days of completing the alteration, the energization certificates for the substation issued by the Alberta Electric System Operator and by AltaLink, respectively, to confirm that the alteration has been completed and is being operated in accordance with the provisions of this permit and licence.

<sup>1</sup> Substation Permit and Licence No. U2011-86, Application No. 1606798, Proceeding ID No. 957, May 3, 2011.

<sup>2</sup> DA 2012-12: AltaLink Management Ltd. Alter Hardisty 377S Substation – Time Extension, Application No. 1608066, Proceeding ID No. 1671, January 23, 2012.

4. Unless otherwise authorized by the Commission alteration of the substation shall be completed by December 31, 2012.
5. The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

Permit and Licence No. U2011-86 is rescinded.

END OF DOCUMENT