


<p>Dated on the</p> <p>7th day of February, 2012</p>	 The Alberta Utilities Commission
Appendix 1 to DA2012-34 ATCO Electric Ltd. Alter Bullpound 803S Substation	Application No. 1608062 Proceeding ID No. 1670

ATCO Electric Ltd. (ATCO), by Application No. 1607521 registered on July 22, 2011, applied to the Alberta Utilities Commission (AUC or the Commission) for approval to replace the existing telecommunications tower at Bullpound 803S substation, located approximately seven kilometres northwest of Finnegan, Alberta. The Commission approved Application No. 1607521 in [DA2011-67](#)¹ on September 19, 2011, and issued Permit and Licence No. [U2011-284](#),² in which the completion date for the alteration was stipulated to be on or before January 31, 2012.

ATCO, by Application No. 1608062 registered on January 18, 2012 (the application), applied to the Commission for an extension of the time to complete the alteration.

The Commission, pursuant to Section 19 of the *Hydro and Electric Energy Act*, approved the application in DA2012-34,³ and pursuant to sections 14 and 15 of the *Hydro and Electric Energy Act*, granted ATCO this permit to alter and a licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The substation shall be wholly located in the northwest quarter of Section 36, Township 25, Range 16, west of the Fourth Meridian.
2. Specifications of the substation shall be:
 - a) one (1) 144/25-kilovolt (kV), 15/20/26 megavolt-ampere transformer
 - b) one (1) 144-kV circuit switcher
 - c) two (2) 25-kV circuit breakers
 - d) one (1) 25-kV voltage regulator
 - e) two (2) 25-kV, 1.2 megavolt-ampere-reactive capacitor banks
 - f) one (1) telecommunications tower with associated communications equipment

¹ DA2011-67: ATCO Electric Ltd. Bullpound 803S Substation Alteration – Letter of enquiry approval, Application No. 1607521, Proceeding ID No. 1364, September 19, 2011.

² Substation Permit and Licence No. U2011-284, Application No. 1607521, Proceeding ID No. 1364, September 19, 2011.

³ DA 2012-34: ATCO Electric Ltd. – Time Extension for Bullpound 803S Substation Alteration, Application No. 1608062, Proceeding ID No. 1670, February 7, 2012.

- g) an enclosure surrounded by a chain link fence and other substation equipment as described in previous applications pertaining to the substation
- 3. ATCO shall file with the Commission, within 30 days of completing the alteration, the energization certificates for the substation issued by the Alberta Electric System Operator and by ATCO, respectively, to confirm that the alteration has been completed and is being operated in accordance with the provisions of this permit and licence.
- 4. Unless otherwise authorized by the Commission alteration of the substation shall be completed by March 28, 2012.

Permit and Licence No. U2011-284 is rescinded.

The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

END OF DOCUMENT