

Substation Permit and Licence 23283-D03-2018

Appendix 2 to Decision 23283-D01-2018	February 9, 2018
AltaLink Management Ltd. Alter Sedgewick 137S Substation	Proceeding 23283 Application 23283-A002

AltaLink Management Ltd. (AltaLink), pursuant to Licence U2002-356,¹ is the operator of Sedgewick 137S Substation located in the Sedgewick area. By Application 23283-A002, registered on January 22, 2018, AltaLink applied to the Alberta Utilities Commission for approval to alter and operate the substation.

The Commission, pursuant to sections 14, 15 and 19 of the *Hydro and Electric Energy Act*, approved the application in Decision 23283-D01-2018² and granted AltaLink a permit to alter and a licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The substation shall be wholly located in the southwest quarter of Section 8, Township 44, Range 12, west of the Fourth Meridian.
2. Specifications of the substation shall be:
 - a) one 138/25-kilovolt (kV), 15/20/25/28-megavolt-ampere transformer
 - b) three 25-kV circuit breakers
 - c) an enclosure surrounded by a chain-link fence and other substation equipment as described in the application and other previous approvals pertaining to the substation
3. AltaLink shall file with the Commission, within 30 days of completing the substation alteration, to confirm that the substation alteration has been completed and the substation is being operated in accordance with the provisions of this permit and licence.

¹ Licence U2002-356, Application 1274771, August 1, 2002.

² Decision 23283-D01-2018: AltaLink Management Ltd. – 25-Kilovolt Circuit Breaker Replacements, Proceeding 23283, Applications 23283-A001 to 23283-A004, February 9, 2018.

4. Unless otherwise authorized by the Commission, alteration of the substation shall be completed by December 31, 2018.

Licence U2002-356 is rescinded.

The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

Alberta Utilities Commission

(original signed by)

Wade Vienneau
Executive Director, Facilities Division
On behalf of the Alberta Utilities Commission.