

## Connection Order 23951-D03-2019

<p>Appendix 2 to Decision 23951-D01-2019</p> <p>Aura Power Renewables Ltd. Connect the Fox Coulee Solar Project to the ATCO Electric Ltd. 25-Kilovolt Electric Distribution System</p>	<p>August 13, 2019</p> <p>Proceeding 23951 Application 23951-A002</p>
--	---

Aura Power Renewables Ltd., registered Application 23951-A002 on October 2, 2018, and applied to the Alberta Utilities Commission for an order to connect the Fox Coulee Solar Project to the ATCO Electric Ltd. 25-kilovolt electric distribution system.

The Commission approved the application in Decision 23951-D01-2019,<sup>1</sup> and granted Aura an order to connect the Fox Coulee Solar Project to the ATCO Electric Ltd. electric distribution system, pursuant to Section 18 of the *Hydro and Electric Energy Act*. This approval is subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. Aura may connect the power plant to the distribution system in the southwest quarter of Section 33, and the southwest quarter of Section 28, Township 29, Range 20, west of the Fourth Meridian, as indicated in the application.
2. The specifications of the connection shall be as set out in the application.
3. The connection shall be operated so that except under short-term emergency conditions:
  - (a) The flows of real and reactive power are those for which the connection is designed and which it is intended to carry on a continuous basis.
  - (b) No excessive surges of 60-hertz power or excessive exchange of power frequency harmonics shall occur between the systems connected.
4. This order is not transferable unless approved by the Commission.

<sup>1</sup> Decision 23951-D01-2019: Aura Power Renewables Ltd. – Fox Coulee Solar Project, Proceeding 23951, Applications 23951-A001 and 23951-A002, August 13, 2019.

The Commission may cancel or suspend this order, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this order, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, within 30 days of the date of this order and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected order on its website.

**Alberta Utilities Commission**

*(original signed by)*

Carolyn Hutniak  
Panel Chair